

From: [REDACTED]
Sent: 19 June 2018 11:00
To: Neighbourhoodplanning
Subject: Maghull Neighbourhood Plan - Regulation 16 Stage

Follow Up Flag: Follow up
Flag Status: Completed

Maghull Neighbourhood Plan – Regulation 16 Stage

Thank you for your email and links to the draft neighbourhood plan.

United Utilities works closely with Sefton Council to understand future development sites and impact on our infrastructure.

It is important that we highlight that as the water and sewerage company for Sefton, we have statutory obligations which include:

- The right to connect domestic wastewater flows to the public sewer. This includes foul and surface water; and
- A domestic supply duty in respect of public water supply.

United Utilities seeks to work with all parties to ensure all surface water from new development is drained in the most sustainable manner, in line with the surface water hierarchy (see specific comments for more detail).

We wish to highlight our **free pre-application service** for applicants to discuss and agree drainage strategies and water supply requirements. We cannot stress highly enough the importance of contacting us as early as possible. Enquiries are encouraged by contacting:

Developer Services - Wastewater

Tel: 03456 723 723

Email: WastewaterDeveloperServices@uuplc.co.uk

Website: <http://www.unitedutilities.com/builder-developer-planning.aspx>

Developer Services – Water

Tel: 0345 072 6067

Email: DeveloperServicesWater@uuplc.co.uk

Website: <http://www.unitedutilities.com/newwatersupply.aspx>

It is important that United Utilities is kept aware of any development proposed within your neighbourhood plan over and above the Council's allocations. We encourage further consultation with us at an early stage should you look to allocate any sites in the future over and above the allocations determined by the council.

Specific Comments

United Utilities recommends additional wording with respect to Surface Water Management. We recommend the following is included in the plan, as a separate policy.

“New development should be designed to maximise the retention of surface water on the development site and to minimise runoff. The approach to surface water drainage should be considered in liaison with the LLFA, the public sewerage undertaker and where appropriate the Environment Agency”.

Surface water should be discharged in the following order of priority:

- *An adequate soakaway or some other form of infiltration system.*
- *An attenuated discharge to watercourse or other water body.*
- *An attenuated discharge to public surface water sewer.*
- *An attenuated discharge to public combined sewer.*

Summary

Moving forward, we respectfully request that Maghull Town Council continue to consult with United Utilities on all future planning documents. We are keen to continue working in partnership with you and Sefton Council to ensure that all new growth can be delivered sustainably.

In the meantime, if you have any queries or would like to discuss this representation, please do not hesitate to contact me.

Kind Regards,

█

█
█
█
Planning Assistant
Developer Services
Network Delivery
United Utilities
T: 01925 7 █ █ █ █
unitedutilities.com

If you have received a great service today why not tell us?
Visit: unitedutilities.com/wow

EMGateway3.uuplc.co.uk made the following annotations

The information contained in this e-mail is intended only for the individual to whom it is addressed. It may contain legally privileged or confidential information or otherwise be exempt from disclosure. If you have received this Message in error or there are any problems, please notify the sender immediately and delete the message from your computer. You must not use, disclose, copy or alter this message for any unauthorised purpose. Neither United Utilities Group PLC nor any of its subsidiaries will be liable for any direct, special, indirect or consequential damages as a result of any virus being passed on, or arising from the alteration of the contents of this message by a third party.

United Utilities Group PLC, Haweswater House, Lingley Mere
Business Park, Lingley Green Avenue, Great Sankey,
Warrington, WA5 3LP
Registered in England and Wales. Registered No 6559020

www.unitedutilities.com
www.unitedutilities.com/subsidiaries
